

BURNHAM ON CROUCH VILLAGE HALL SPECIAL CONDITIONS USE OF STAGE AND STAGE LIGHTING

1. THE STAGE

The Committee regrets that at present there is no disabled access to the stage and no stage curtains. It is hoped that these facilities will be restored when funds permit. Hirers using the stage are requested to read carefully paragraph number 6 of the Burnham on Crouch Village Hall Special Conditions.

2. STAGE LIGHTING

The stage lighting system uses extremely expensive and delicate equipment which is easily damaged by improper use.

The stage lighting MUST, therefore, be operated only by persons having suitable competency. If there is any doubt about this, the advice of the Management Committee MUST be sought before the hiring commences.

ANY DAMAGE RESULTING FROM MISUSE WILL BE CHARGEABLE TO THE HIRER.

The lighting comprises a number of lamps hung on three bars above the stage at the front, middle and back of the stage.

The lighting is controlled from the cupboard situated at the front left of the stage, as viewed from the stage. The controls comprise an electronic switchboard together with two electronic dimmer packs.

Power is supplied by a dedicated 60amp supply and terminated in two 60amp sockets in the cupboard. The large plugs on the dimmer packs must be inserted into the sockets before use. **HIRERS ARE REQUIRED TO ENSURE THAT THESE PLUGS ARE REMOVED AND THE CUPBOARD LOCKED BEFORE THEY LEAVE THE PREMISES. THERE ARE NO OTHER SWITCHES CONTROLLING THE SUPPLY TO THE STAGE LIGHTING.**

A plan of the system is attached to the inside of the cupboard door which ensures that the system is capable of being understood and operated by any competent person.

Reviewed in January 2016